

**OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY  
TURBIDITY TRIGGER EVALUATION FORM**

**SYSTEMS WITH A POPULATION <= 10,000**

SYSTEM \_\_\_\_\_

PLANT \_\_\_\_\_

ADDRESS \_\_\_\_\_

PWSID \_\_\_\_\_

CITY/ZIP \_\_\_\_\_

MONTH \_\_\_\_\_

THIS FORM IS REQUIRED IF ANY INDIVIDUAL FILTER TURBIDITY TRIGGERS HAVE BEEN EXCEEDED DURING THE MONTH, OR, IF ANY TURBIDITY TRIGGERS FROM THE COMBINED FILTER EFFLUENT TURBIDITY (FOR PLANTS WITH ONLY 2 OR FEWER FILTERS WHO HAVE CHOSEN TO USE THE COMBINED FILTER EFFLUENT TURBIDITY FOR COMPLIANCE WITH THE TURBIDITY TRIGGERS) HAVE BEEN EXCEEDED.

LIST ALL TURBIDITY MEASUREMENTS GREATER THAN 1.0 NTU:

<b>Date</b>	<b>Time</b>	<b>Filter #</b>	<b>Turbidity</b>	<b>Cause of Filter Exceedance<sup>1</sup></b>	<b>Date of Filter Profile and Self-Assessment<sup>2</sup></b>	<b>Date CPE Scheduled<sup>3</sup></b>	<b>Comments:</b>

<sup>1</sup> A turbidity trigger form [filter number(s), corresponding date(s), turbidity value(s) which exceeded 1.0 NTU, and the cause (if known) for the exceedance(s)] is to be submitted to DEQ by the 10<sup>th</sup> of the following month if:

- A single filter turbidity or combined filter effluent turbidity exceeds 1.0 NTU in two consecutive 15-minute periods.

<sup>2</sup> A filter profile and self-assessment is required if:

- A single filter turbidity or combined filter effluent turbidity exceeds 1.0 NTU in two consecutive 15-minute periods during three consecutive months.

<sup>3</sup> A CPE is required to be requested within 60 days if:

- A single filter turbidity or combined filter effluent turbidity exceeds 2.0 NTU in two consecutive 15-minute periods during two consecutive months.

FORM COMPLETED BY: \_\_\_\_\_

OPERATOR LICENSE NUMBER: \_\_\_\_\_