

**DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY MANAGEMENT ADVISORY COUNCIL  
REGULAR MEETING**

**AGENDA**

*Please silence all cell phones*

Public Meeting:        January 14, 2014, at 1:00 p.m.  
                                 Department of Environmental Quality

Location:                Multi-Purpose Room, 1<sup>st</sup> Floor  
                                 DEQ Building  
                                 707 N. Robinson  
                                 Oklahoma City, Oklahoma

1.     CALL TO ORDER - Mike Paque
2.     INTRODUCTION OF NEW COUNCIL MEMBERS, TERRY WYATT, ROBERT CARR,  
       AND GREG McCORTNEY – Shellie Chard-McClary
3.     ROLL CALL - Quiana Fields
4.     APPROVAL OF MINUTES FROM THE OCTOBER 8, 2013 MEETING
5.     ELECTION OF THE VICE-CHAIR - Mike Paque
  - A.    Nominations
  - B.    Discussion
  - C.    Vote
6.     ELECTION OF THE CHAIR – Newly Elected Vice-Chair
  - A.    Nominations
  - B.    Discussion
  - C.    Vote
7.     PERMANENT RULEMAKING – OAC 252:606 – “OKLAHOMA POLLUTANT  
       DISCHARGE ELIMINATION SYSTEM (OPDES) STANDARDS.”

The Department is proposing to: (1) update the numbering of subparagraphs incorporated by reference in 40 CFR 124.10 to be consistent with the current CFR; (2) replace the provision for pro-rating the initial stormwater permit fees with a provision allowing the initial fee to cover the subsequent 12 months; and (3) revoke Appendix D and move the fee language to Section 3-4.

- A.    Presentation – Mark Hildebrand
- B.    Discussion by the Council
- C.    Discussion by the Public

- D. Additional Discussion by the Council
- E. Vote

8. PERMANENT RULEMAKING – OAC 252:656 – “WATER POLLUTION CONTROL FACILITY CONSTRUCTION STANDARDS.”

The Department is proposing to: (1) require that the submission of plans include at least one set of construction plans be on 11" x 17" paper and one set of specifications be loosely bound and suitable for scanning; (2) strengthen the existing prohibition against locating lagoons in areas subject to karstification; (3) add disinfection criteria for reclaimed water systems and distinguish those criteria from the criteria required for OPDES discharges; (4) clarify that the minimum dosage for Category 3 reclaimed water design is based on MS-2 phage inactivation; (5) add traveling bridge filters as an approved method for filtration; (6) update the hydraulic loading rates for disc filters; (7) require a pilot study before designing filters to be used to polish TSS from lagoon effluent; (8) add a requirement for signage around water reuse land application sites; (9) clarify that fencing is required for Category 5 reclaimed water land application sites; (10) add a requirement for above-ground signage for existing reclaimed water piping that does not meet the purple pipe standards; and (11) make other minor clarifications and typographical corrections.

- A. Presentation – Mark Hildebrand
- B. Discussion by the Council
- C. Discussion by the Public
- D. Additional Discussion by the Council
- E. Vote

9. PERMANENT RULEMAKING – OAC 252:710 – “WATERWORKS AND WASTEWATER WORKS OPERATOR CERTIFICATION.”

The Department is proposing to clarify that an entity only needs to meet one of the listed conditions set forth for a particular classification level in order to fall under that classification.

- A. Presentation – Mark Hildebrand
- B. Discussion by the Council
- C. Discussion by the Public
- D. Additional Discussion by the Council
- F. Vote

10. DIRECTOR’S REPORT – Shellie Chard-McClary

11. NEW BUSINESS – New Chair

Only those matters not known about and which could not have been reasonably foreseen at the time of the posting of this agenda shall be discussed at this time.

12. ANNOUNCEMENTS

Next Scheduled Meeting – July 8, 2014, 1:00 p.m., Multi-Purpose Room, 1<sup>st</sup> Floor, DEQ Building, 707 N. Robinson, Oklahoma City, Oklahoma

13. ADJOURNMENT

**Should you have a disability and need an accommodation, please notify Mark Hildebrand of the DEQ three days in advance at 702-8100.**